

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
King Elementary School - Test 8**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
262-DF-1702-N/A-008-A	Classroom 142	10/21/2021	10/26/2021	A1J0814-01	Lead	5.37	0.2	15	ppb
262-DF-1699-N/A-008-A	Classroom 141	10/21/2021	10/26/2021	A1J0814-02	Lead	2.66	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb