

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn Elementary School - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-DF-1274-A-005-A	Hallway (Classroom 101)	10/15/2021	10/28/2021	A1J0680-11	Lead	ND	0.2	15	ppb
269-DF-5992-N/A-005-A	Health Room	10/15/2021	10/27/2021	A1J0680-12	Lead	0.468	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb