

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Markham Site - Test 4**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
170-DF-3907-A-004-A	Cafeteria	7/27/2022	7/29/2022	A2G0761-02	Lead	ND	0.200	15	ppb
170-DF-3924-A-004-A	Hallway (Classroom 131)	7/27/2022	7/29/2022	A2G0761-07	Lead	ND	0.200	15	ppb
170-DF-3936-A-004-A	Auditorium Entry	7/27/2022	7/29/2022	A2G0761-06	Lead	ND	0.200	15	ppb
170-DF-3947-A-004-A	Autidorium Entry	7/27/2022	7/29/2022	A2G0761-04	Lead	ND	0.200	15	ppb
170-DF-3950-A-004-A	Hallway (Classroom 161)	7/27/2022	7/29/2022	A2G0761-03	Lead	ND	0.200	15	ppb
170-DF-6030-N/A-004-A	Staff Room (Room 137)	7/27/2022	7/29/2022	A2G0761-05	Lead	0.550	0.200	15	ppb
170-DF-6033-N/A-004-A	Kitchen	7/27/2022	7/29/2022	A2G0761-01	Lead	0.220	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1