

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Marshall Site - Test 6**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
220-DF5271-A-006-A	Weight room	7/12/2022	7/14/2022	A2G0387-01	Lead	0.773	0.200	15	ppb
220-DF5274-A-006-A	Gym (G4)	7/12/2022	7/14/2022	A2G0387-02	Lead	0.660	0.200	15	ppb
220-DF5280-A-006-A	Gym A33	7/12/2022	7/14/2022	A2G0387-03	Lead	0.539	0.200	15	ppb
220-DF5283-A-006-A	Gym A34	7/12/2022	7/14/2022	A2G0387-04	Lead	0.807	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb