

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Tubman Middle School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
199-DF-2104-N/A-003-A	Staff Room	12/21/2021	12/28/2021	A1L0803-01	Lead	0.510	0.2	15	ppb
199-DF-5869-N/A-003-A	Kitchen	12/21/2021	12/30/2021	A1L0803-02	Lead	ND	0.2	15	ppb
199-DF-5868-N/A-003-A	ISC	12/21/2021	12/30/2021	A1L0803-03	Lead	0.992	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek