

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Laurelhurst K-8 School - Test 7**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
265-DF-3745-A-007-A	Hallway (218)	12/21/2021	12/28/2021	A1L0803-12	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb