

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Kelly Elementary School - Test 5**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detection Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
258-DF-5885-N/A-004-A	Kitchen	12/21/2021	12/28/2021	A1L0803-05	Lead	1.28	0.2	15	ppb
258-DF-5888-N/A-004-A	Staff Room	12/21/2021	12/28/2021	A1L0803-06	Lead	0.226	0.2	15	ppb
258-DF-5889-N/A-004-A	Headstart 29	12/21/2021	12/28/2021	A1L0803-07	Lead	0.380	0.2	15	ppb
258-DF-5896-N/A-004-A	Headstart 6B	12/21/2021	12/28/2021	A1L0803-08	Lead	0.310	0.2	15	ppb
258-DF-5895-N/A-004-A	Headstart 2	12/21/2021	12/28/2021	A1L0803-09	Lead	0.853	0.2	15	ppb
258-DF-5894-N/A-004-A	Staff Room	12/21/2021	12/28/2021	A1L0803-10	Lead	0.314	0.2	15	ppb

Analyzed by: Apex Laboratories  
Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb