

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Marysville Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
268-DF-5899-A-004-A	Hallway (Staff Room)	12/10/2021	12/21/2021	A1L0432-16	Lead	ND	0.2	15	ppb
268-DF-5456-A-004-A	Hallway (Gym)	12/10/2021	12/21/2021	A1L0432-17	Lead	ND	0.2	15	ppb
268-DF-5504-N/A-004-A	SES Classroom	12/10/2021	12/21/2021	A1L0432-18	Lead	1.69	0.2	15	ppb
268-DF-5332-N/A-004-A	SES Classroom	12/10/2021	12/21/2021	A1L0432-19	Lead	0.935	0.2	15	ppb
268-DF-5326-A-004-A	Hallway (Classroom 121)	12/10/2021	12/21/2021	A1L0432-20	Lead	ND	0.2	15	ppb
268-DF-5346-A-004-A	Hallway (Classroom 105)	12/10/2021	12/21/2021	A1L0432-21	Lead	ND	0.2	15	ppb
268-DF-5901-N/A-004-A	Kitchen	12/10/2021	12/21/2021	A1L0432-22	Lead	0.224	0.2	15	ppb
268-DF-5990-N/A-004-A	Staff Room	12/10/2021	12/21/2021	A1L0432-23	Lead	1.32	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb