

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Winterhaven K-8 School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
239-DF-6018-N/A-004-A	Kitchen	12/10/2021	12/23/2021	A1L0432-10RE1	Lead	ND	0.2	15	ppb
239-DF-1370-A-004-A	Hallway (Classroom 1)	12/10/2021	12/21/2021	A1L0432-11	Lead	1.97	0.2	15	ppb
239-DF-1373-A-004-A	Hallway (Library)	12/10/2021	12/21/2021	A1L0432-12	Lead	ND	0.2	15	ppb
239-DF-1138-A-004-A	Hallway (Kindergarten 8)	12/10/2021	12/21/2021	A1L0432-13	Lead	ND	0.2	15	ppb
239-DF-1374-A-004-A	Hallway (Classroom 27)	12/10/2021	12/21/2021	A1L0432-14	Lead	ND	0.2	15	ppb
239-DF-1376-A-004-A	Hallway (Computer Lab)	12/10/2021	12/21/2021	A1L0432-15	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek