

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
da Vinci Middle School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
365-DF-4600-A-005-A	Hallway (Classroom 206)	12/10/2021	12/21/2021	A1L0432-01	Lead	ND	0.2	15	ppb
365-DF-4603-A-005-A	Hallway (Classroom 204)	12/10/2021	12/21/2021	A1L0432-02	Lead	ND	0.2	15	ppb
365-DF-4617-A-005-A	Hallway (Classroom 102)	12/10/2021	12/21/2021	A1L0432-03	Lead	ND	0.2	15	ppb
365-DF-6013-N/A-005-A	Kitchen	12/10/2021	12/21/2021	A1L0432-04	Lead	ND	0.2	15	ppb
365-DF-4599-A-005-A	Hallway (Classroom 104)	12/10/2021	12/21/2021	A1L0432-05	Lead	ND	0.2	15	ppb
365-DF-4594-A-005-A	Hallway (Classroom 106)	12/10/2021	12/21/2021	A1L0432-06RE2	Lead	ND	0.2	15	ppb
365-DF-4620-A-005-A	Hallway (Library)	12/10/2021	12/21/2021	A1L0432-07	Lead	ND	0.2	15	ppb
365-DF-4625-A-005-A	Hallway (Classroom 302)	12/10/2021	12/21/2021	A1L0432-08	Lead	ND	0.2	15	ppb
365-DF-4612-A-005-A	Auditorium Stage	12/10/2021	12/21/2021	A1L0432-09	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb