

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Bridlemile Elementary - Test 5**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
142-DF6063-A-005-A	Hallway (Classroom 32)	8/2/2022	8/8/2022	A2H0125-01	Lead	0.865	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb