

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Glencoe - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
157-DF1740-A-003-A	Gym	6/3/2022	6/7/2022	A2F0151-04	Lead	0.294	0.222	15	ppb
157-DF1746-A-003-A	Hallway (102)	6/3/2022	6/7/2022	A2F0151-03	Lead	ND	0.200	15	ppb
157-DF1749-A-003-A	Hallway (104)	6/3/2022	6/7/2022	A2F0151-05	Lead	ND	0.200	15	ppb
157-DF1751-A-003-A	Hallway (204)	6/3/2022	6/7/2022	A2F0151-07	Lead	ND	0.200	15	ppb
157-DF1753-A-003-A	Cafeteria	6/3/2022	6/7/2022	A2F0151-02	Lead	ND	0.200	15	ppb
157-DF5915-N/A-003-A	Staff Room	6/3/2022	6/7/2022	A2F0151-08	Lead	ND	0.200	15	ppb
157-DF5916-N/A-003-A	Hallway (210)	6/3/2022	6/7/2022	A2F0151-01	Lead	0.292	0.200	15	ppb
157-DF5917-N/A-003-A	Hallway (210)	6/3/2022	6/7/2022	A2F0151-06	Lead	0.792	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental