

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Mt. Tabor - Test 4**

| Sample Identification # | Location            | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detecti on Limit | PPS Action Level* | Units |
|-------------------------|---------------------|---------------------|---------------|------------|---------|---------|------------------|-------------------|-------|
| 176-DF-3678-A-004-A     | Hallway (Cafeteria) | 5/27/2022           | 6/3/2022      | A2E1016-08 | Lead    | ND      | 0.200            | 15                | ppb   |
| 176-DF-3698-A-004-A     | Cafeteria           | 5/27/2022           | 6/3/2022      | A2E1016-10 | Lead    | ND      | 0.200            | 15                | ppb   |
| 176-DF-5918-A-004-A     | Hallway (101)       | 5/27/2022           | 6/3/2022      | A2E1016-01 | Lead    | ND      | 0.200            | 15                | ppb   |
| 176-DF-5919-A-004-A     | Hallway (113)       | 5/27/2022           | 6/10/2022     | A2E1016-02 | Lead    | ND      | 0.222            | 15                | ppb   |
| 176-DF-5920-N/A-004-A   | ISC                 | 5/27/2022           | 6/10/2022     | A2E1016-03 | Lead    | 0.596   | 0.222            | 15                | ppb   |
| 176-DF-5921-N/A-004-A   | Kitchen             | 5/27/2022           | 6/10/2022     | A2E1016-11 | Lead    | ND      | 0.222            | 15                | ppb   |
| 176-DF-5922-A-004-A     | Hallway (200)       | 5/27/2022           | 6/3/2022      | A2E1016-06 | Lead    | ND      | 0.200            | 15                | ppb   |
| 176-DF-5923-N/A-004-A   | Main Office         | 5/27/2022           | 6/3/2022      | A2E1016-09 | Lead    | 0.530   | 0.200            | 15                | ppb   |
| 176-DF-5924-N/A-004-A   | Staff Room          | 5/27/2022           | 6/10/2022     | A2E1016-07 | Lead    | 0.570   | 0.222            | 15                | ppb   |
| 176-DF-5925-N/A-004-A   | Health Room         | 5/27/2022           | 6/10/2022     | A2E1016-12 | Lead    | 0.291   | 0.222            | 15                | ppb   |
| 176-DF-5926-A-004-A     | Hallway (209)       | 5/27/2022           | 6/3/2022      | A2E1016-05 | Lead    | ND      | 0.200            | 15                | ppb   |
| 176-DF-5927-A-004-A     | Hallway (214)       | 5/27/2022           | 6/3/2022      | A2E1016-04 | Lead    | ND      | 0.200            | 15                | ppb   |

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1