

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Terwilliger Site - Test 3**

| Sample Identification # | Location | Date/Time Collected | Date Analyzed | Lab ID | Analyte | Results | Detecti on Limit | PPS Action Level* | Units |
|--------------------------------|-----------------------|----------------------------|----------------------|---------------|----------------|----------------|-------------------------|--------------------------|--------------|
| 366-DF-2221-A-003-A | Hallway (Classroom 1) | 8/18/2022 | 8/26/2022 | A2H0743-01 | Lead | ND | 0.200 | 15 | ppb |
| 366-DF-2224-A-003-A | Hallway (Reception 6) | 8/18/2022 | 8/26/2022 | A2H0743-02 | Lead | ND | 0.200 | 15 | ppb |

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb