

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Applegate Site - Test 4**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
134-DF3054-NA-004-A	Headstart Classroom 6	8/9/2022	8/12/2022	A2H0336-08	Lead	1.56	0.222	15	ppb
134-DF3059-NA-004-A	Headstart Classroom 11	8/9/2022	8/12/2022	A2H0336-04RE1	Lead	ND	0.200	15	ppb
134-DF3060-NA-004-A	Headstart Classroom 4	8/9/2022	8/12/2022	A2H0336-05RE1	Lead	2.34	0.200	15	ppb
134-DF3062-NA-004-A	Headstart Classroom 10	8/9/2022	8/12/2022	A2H0336-02RE1	Lead	1.74	0.200	15	ppb
134-DF3066-A-004-A	Hallway (Gym 2)	8/9/2022	8/12/2022	A2H0336-06RE1	Lead	ND	0.200	15	ppb
134-DF3069-NA-004-A	Early Headstart Portable	8/9/2022	8/12/2022	A2H0336-03RE1	Lead	9.35	0.200	15	ppb
134-DF3071-NA-004-A	Headstart Classroom 8	8/9/2022	8/12/2022	A2H0336-07RE1	Lead	0.387	0.200	15	ppb
134-DF3074-A-004-A	Hallway (Classroom 7)	8/9/2022	8/12/2022	A2H0336-09RE1	Lead	ND	0.200	15	ppb
134-DF6156-NA-004-A	Family Service	8/9/2022	8/12/2022	A2H0336-01RE1	Lead	0.876	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb

Page 1 of 1

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Applegate Site - Test 4**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
134-DF3057-NA-004-A	Headstart Classroom 5	8/9/2022	8/16/2022	A2H0348-03	Lead	1.16	0.2	15	ppb
134-DF3068-NA-004-A	Headstart Classroom 9	8/9/2022	8/16/2022	A2H0348-02	Lead	0.992	0.2	15	ppb
134-DF3077-NA-004-A	Headstart Classroom 7	8/9/2022	8/16/2022	A2H0348-04	Lead	0.400	0.2	15	ppb
134-DF6158-NA-004-A	Kitchen	8/9/2022	8/16/2022	A2H0348-01	Lead	0.706	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb