

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
King Site - Test 10**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
262-DF6129-NA-010-A	Staff Room (Annex)	8/4/2022	8/8/2022	A2H0181-02	Lead	0.252	0.200	15	ppb
262-DF6130-NA-010-A	Annex Special Ed. Classroom	8/4/2022	8/8/2022	A2H0181-03	Lead	ND	0.200	15	ppb
262-DF6131-A-010-A	Hallway (Annex)	8/4/2022	8/8/2022	A2H0181-01	Lead	1.11	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb