

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Maplewood Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
172-DF-6090-A-005-A	Outside (Portable 1)	8/4/2022	8/12/2022	A2H0197-01RE1	Lead	1.20	0.2	15	ppb
172-DF-6094-NA-005-A	Office	8/4/2022	8/12/2022	A2H0197-02RE1	Lead	0.429	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1