

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Roosevelt Site - Test 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
124-DF2875-NA-002-A	Hallway (Science Lab 15)	8/9/2022	8/12/2022	A2H0337-01RE1	Lead	ND	0.200	15	ppb
124-DF2881-NA-002-A	Hallway (Science Lab 25)	8/9/2022	8/12/2022	A2H0337-02RE1	Lead	ND	0.200	15	ppb
124-DF2884-NA-002-A	Hallway (Remote Server)	8/9/2022	8/12/2022	A2H0337-03RE1	Lead	ND	0.200	15	ppb
124-DF2889-NA-002-A	Hallway (Science Lab 05)	8/9/2022	8/12/2022	A2H0337-04RE1	Lead	ND	0.200	15	ppb
124-DF6311-NA-002-A	Teachers Planning 271	8/9/2022	8/12/2022	A2H0337-06RE1	Lead	0.665	0.200	15	ppb
124-DF6312-NA-002-A	Teachers Planning 229	8/9/2022	8/12/2022	A2H0337-07RE1	Lead	0.211	0.200	15	ppb
124-DF6313-NA-002-A	Teachers Planning 207	8/9/2022	8/12/2022	A2H0337-08RE1	Lead	0.456	0.200	15	ppb
124-DF6315-NA-002-A	Teachers Planning 226	8/9/2022	8/12/2022	A2H0337-09RE1	Lead	0.272	0.200	15	ppb
124-DF6316-NA-002-A	Teachers Planning 013	8/9/2022	8/12/2022	A2H0337-10RE1	Lead	0.724	0.200	15	ppb
124-DF6318-NA-002-A	Custodian Break Room 0	8/9/2022	8/12/2022	A2H0337-11RE1	Lead	4.59	0.200	15	ppb
124-DF6320-NA-002-A	Kitchen 025	8/9/2022	8/12/2022	A2H0337-05RE1	Lead	ND	0.200	15	ppb
124-DF6321-NA-002-A	Concessions 074	8/9/2022	8/12/2022	A2H0337-12RE1	Lead	0.473	0.200	15	ppb
124-DF6322-NA-002-A	Life Skills 059	8/9/2022	8/12/2022	A2H0337-13	Lead	0.454	0.200	15	ppb
124-DF6324-NA-002-A	Teachers Planning 056	8/9/2022	8/12/2022	A2H0337-14	Lead	0.952	0.200	15	ppb
124-DF6325-NA-002-A	Teachers Planning 034	8/9/2022	8/12/2022	A2H0337-15	Lead	0.611	0.200	15	ppb
124-DF6326-NA-002-A	Teachers Planning 158	8/9/2022	8/12/2022	A2H0337-16	Lead	2.24	0.200	15	ppb
124-DF6327-NA-002-A	Teachers Planning 138	8/9/2022	8/12/2022	A2H0337-17	Lead	ND	0.200	15	ppb
124-DF6328-NA-002-A	Student Coffee Shop 104	8/9/2022	8/12/2022	A2H0337-18	Lead	0.473	0.200	15	ppb
124-DF6329-NA-002-A	Nurse 106	8/9/2022	8/12/2022	A2H0337-19	Lead	0.337	0.200	15	ppb
124-DF6330-NA-002-A	Family Room 105F	8/9/2022	8/13/2022	A2H0337-20	Lead	0.746	0.200	15	ppb
124-DF6331-NA-002-A	Toddler 107J	8/9/2022	8/13/2022	A2H0337-21	Lead	0.835	0.200	15	ppb
124-DF6332-NA-002-A	Kitchen 107D	8/9/2022	8/13/2022	A2H0337-22	Lead	ND	0.200	15	ppb
124-DF6333-NA-002-A	Crawler 107G	8/9/2022	8/13/2022	A2H0337-23	Lead	2.19	0.200	15	ppb
124-DF6334-NA-002-A	Infant 107F	8/9/2022	8/12/2022	A2H0337-24	Lead	2.79	0.222	15	ppb
124-DF6335-NA-002-A	Teacher's Lunch 109L	8/9/2022	8/13/2022	A2H0337-25	Lead	0.212	0.200	15	ppb
124-DF6336-NA-002-A	Lunch Room 113A	8/9/2022	8/13/2022	A2H0337-26	Lead	0.493	0.200	15	ppb

Analyzed by: Apex Laboratories

\*OHA Action Level = 15ppb

Reviewed by: PBS Engineering and Environmental

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Roosevelt Site - Test 2**

<b>Sample Identification #</b>	<b>Location</b>	<b>Date/Time Collected</b>	<b>Date Analyzed</b>	<b>Lab ID</b>	<b>Analyte</b>	<b>Results</b>	<b>Detecti on Limit</b>	<b>PPS Action Level*</b>	<b>Units</b>
124-DF6337-NA-002-A	Lunch Room 115H	8/9/2022	8/13/2022	A2H0337-27	Lead	0.406	0.200	15	ppb
124-DF6338-NA-002-A	Teachers Planning 11	8/9/2022	8/13/2022	A2H0337-28	Lead	1.09	0.200	15	ppb
124-DF6339-NA-002-A	Teachers Planning 250	8/9/2022	8/13/2022	A2H0337-29	Lead	0.216	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

\*OHA Action Level = 15ppb