

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sunnyside Site - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
191-DF-3788-A-006-A	Hallway (105)	9/28/2022	9/29/2022	A2I0877-01	Lead	ND	0.200	15	ppb
191-DF-3792-A-006-A	Hallway (207)	9/28/2022	9/29/2022	A2I0877-02	Lead	ND	0.200	15	ppb
191-DF5928-NA-006-A	Staff Room	9/28/2022	9/29/2022	A2I0877-04	Lead	1.18	0.222	15	ppb
191-DF-5931-A-006-A	Hallway (110)	9/28/2022	9/29/2022	A2I0877-03	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb