

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Sunnyside Site - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detecti on Limit	PPS Action Level*	Units
191-DF3806-A-005-A	Hallway (204)	9/16/2022	9/19/2022	A2I0528-01	Lead	ND	0.200	15	ppb
191-DF3835-A-005-A	Hallway (104)	9/16/2022	9/19/2022	A2I0528-02	Lead	ND	0.200	15	ppb
191-DF5929-A-005-A	Cafeteria	9/16/2022	9/19/2022	A2I0528-03	Lead	ND	0.200	15	ppb
191-DF5930-NA-005-A	Kitchen	9/16/2022	9/19/2022	A2I0528-04	Lead	0.426	0.200	15	ppb
191-DF5932-NA-005-A	Staff Room	9/16/2022	9/19/2022	A2I0528-05	Lead	0.610	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*OHA Action Level = 15ppb

Page 1 of 1