

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Sacajawea Head Start

| Sample Identification # | Location | Date Collected | Date Analyzed | Lab ID | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|--|----------------|---------------|---------------|---------|---------|-----------------|-------------------|-------|
| 368-2218-N/A-001-A | Drinking Fountain (Metal) - Hallway by Kitchen | 8/30/2018 | 9/10/2018 | A8H0860-01RE1 | Copper | 1.39 | 0.0100 | 1.3 | ppm |
| 368-2218-N/A-001-A | Drinking Fountain (Metal) - Hallway by Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-01 | Lead | 72.3 | 0.200 | 15 | ppb |
| 368-2218-N/A-001-B | Drinking Fountain (Metal) - Hallway by Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-02 | Copper | 0.168 | 0.00200 | 1.3 | ppm |
| 368-2218-N/A-001-B | Drinking Fountain (Metal) - Hallway by Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-02 | Lead | 7.73 | 0.200 | 15 | ppb |
| 368-2216-A-001-A | Food Prep Sprayer - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-03 | Copper | 0.155 | 0.00200 | 1.3 | ppm |
| 368-2216-A-001-A | Food Prep Sprayer - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-03 | Lead | 3.12 | 0.200 | 15 | ppb |
| 368-2216-A-001-B | Food Prep Sprayer - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-04 | Copper | 0.0515 | 0.00200 | 1.3 | ppm |
| 368-2216-A-001-B | Food Prep Sprayer - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-04 | Lead | 1.20 | 0.200 | 15 | ppb |
| 368-2216-B-001-A | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-05 | Copper | 0.188 | 0.00200 | 1.3 | ppm |
| 368-2216-B-001-A | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-05 | Lead | 3.28 | 0.200 | 15 | ppb |
| 368-2216-B-001-B | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-06 | Copper | 0.0674 | 0.00200 | 1.3 | ppm |
| 368-2216-B-001-B | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-06 | Lead | 1.18 | 0.200 | 15 | ppb |
| 368-2217-N/A-001-A | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-07 | Copper | 0.175 | 0.00200 | 1.3 | ppm |
| 368-2217-N/A-001-A | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-07 | Lead | 6.93 | 0.200 | 15 | ppb |
| 368-2217-N/A-001-B | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-08 | Copper | 0.0233 | 0.00200 | 1.3 | ppm |
| 368-2217-N/A-001-B | Food Prep Faucet - Kitchen | 8/30/2018 | 9/6/2018 | A8H0860-08 | Lead | 2.38 | 0.200 | 15 | ppb |
| 368-2214-N/A-001-A | Classroom Sink Bubbler - Classroom 106 | 8/30/2018 | 9/6/2018 | A8H0860-09 | Copper | 0.0638 | 0.00200 | 1.3 | ppm |
| 368-2214-N/A-001-A | Classroom Sink Bubbler - Classroom 106 | 8/30/2018 | 9/6/2018 | A8H0860-09 | Lead | 13.9 | 0.200 | 15 | ppb |
| 368-2214-N/A-001-B | Classroom Sink Bubbler - Classroom 106 | 8/30/2018 | 9/6/2018 | A8H0860-10 | Copper | 0.0356 | 0.00200 | 1.3 | ppm |
| 368-2214-N/A-001-B | Classroom Sink Bubbler - Classroom 106 | 8/30/2018 | 9/10/2018 | A8H0860-10RE1 | Lead | 3.56 | 0.200 | 15 | ppb |
| 368-2219-N/A-001-A | Classroom Sink Bubbler - Classroom 108 | 8/30/2018 | 9/6/2018 | A8H0860-11 | Copper | 0.0286 | 0.00200 | 1.3 | ppm |
| 368-2219-N/A-001-A | Classroom Sink Bubbler - Classroom 108 | 8/30/2018 | 9/10/2018 | A8H0860-11RE1 | Lead | 11.7 | 0.200 | 15 | ppb |
| 368-2219-N/A-001-B | Classroom Sink Bubbler - Classroom 108 | 8/30/2018 | 9/6/2018 | A8H0860-12 | Copper | 0.0124 | 0.00200 | 1.3 | ppm |

Analyzed by: Apex Laboratories
Reviewed by: G2 Consultants, Inc.

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

| | | | | | | | | | |
|--------------------|--|-----------|-----------|---------------|--------|---------|---------|-----|-----|
| 368-2219-N/A-001-B | Classroom Sink Bubbler - Classroom 108 | 8/30/2018 | 9/10/2018 | A8H0860-12RE1 | Lead | 3.52 | 0.200 | 15 | ppb |
| 368-2213-N/A-001-A | Classroom Sink Bubbler - Classroom 105 | 8/30/2018 | 9/6/2018 | A8H0860-13 | Copper | 0.0223 | 0.00200 | 1.3 | ppm |
| 368-2213-N/A-001-A | Classroom Sink Bubbler - Classroom 105 | 8/30/2018 | 9/10/2018 | A8H0860-13RE1 | Lead | 3.04 | 0.200 | 15 | ppb |
| 368-2213-N/A-001-B | Classroom Sink Bubbler - Classroom 105 | 8/30/2018 | 9/6/2018 | A8H0860-14 | Copper | 0.0115 | 0.00200 | 1.3 | ppm |
| 368-2213-N/A-001-B | Classroom Sink Bubbler - Classroom 105 | 8/30/2018 | 9/10/2018 | A8H0860-14RE1 | Lead | 2.16 | 0.200 | 15 | ppb |
| 368-2212-N/A-001-A | Classroom Sink Bubbler - Classroom 104 | 8/30/2018 | 9/6/2018 | A8H0860-15 | Copper | 0.0217 | 0.00200 | 1.3 | ppm |
| 368-2212-N/A-001-A | Classroom Sink Bubbler - Classroom 104 | 8/30/2018 | 9/10/2018 | A8H0860-15RE1 | Lead | 16.1 | 0.200 | 15 | ppb |
| 368-2212-N/A-001-B | Classroom Sink Bubbler - Classroom 104 | 8/30/2018 | 9/6/2018 | A8H0860-16 | Copper | 0.00878 | 0.00200 | 1.3 | ppm |
| 368-2212-N/A-001-B | Classroom Sink Bubbler - Classroom 104 | 8/30/2018 | 9/10/2018 | A8H0860-16RE1 | Lead | 7.80 | 0.200 | 15 | ppb |
| 368-2220-A-001-A | Classroom Sink Faucet - Classroom 109 | 8/30/2018 | 9/6/2018 | A8H0860-17 | Copper | 0.0397 | 0.00200 | 1.3 | ppm |
| 368-2220-A-001-A | Classroom Sink Faucet - Classroom 109 | 8/30/2018 | 9/10/2018 | A8H0860-17RE1 | Lead | 52.5 | 0.200 | 15 | ppb |
| 368-2220-A-001-B | Classroom Sink Faucet - Classroom 109 | 8/30/2018 | 9/6/2018 | A8H0860-18 | Copper | 0.0185 | 0.00200 | 1.3 | ppm |
| 368-2220-A-001-B | Classroom Sink Faucet - Classroom 109 | 8/30/2018 | 9/10/2018 | A8H0860-18RE1 | Lead | 16.6 | 0.200 | 15 | ppb |
| 368-2220-B-001-A | Classroom Sink Bubbler - Classroom 109 | 8/30/2018 | 9/6/2018 | A8H0860-19 | Copper | 0.120 | 0.00200 | 1.3 | ppm |
| 368-2220-B-001-A | Classroom Sink Bubbler - Classroom 109 | 8/30/2018 | 9/10/2018 | A8H0860-19RE1 | Lead | 4.86 | 0.200 | 15 | ppb |
| 368-2220-B-001-B | Classroom Sink Bubbler - Classroom 109 | 8/30/2018 | 9/6/2018 | A8H0860-20 | Copper | 0.0117 | 0.00200 | 1.3 | ppm |
| 368-2220-B-001-B | Classroom Sink Bubbler - Classroom 109 | 8/30/2018 | 9/10/2018 | A8H0860-20RE1 | Lead | 2.17 | 0.200 | 15 | ppb |
| 368-2211-N/A-001-A | Classroom Sink Bubbler - Classroom 103 | 8/30/2018 | 9/6/2018 | A8H0860-21 | Copper | 0.0384 | 0.00200 | 1.3 | ppm |
| 368-2211-N/A-001-A | Classroom Sink Bubbler - Classroom 103 | 8/30/2018 | 9/10/2018 | A8H0860-21RE1 | Lead | 6.90 | 0.200 | 15 | ppb |
| 368-2211-N/A-001-B | Classroom Sink Bubbler - Classroom 103 | 8/30/2018 | 9/6/2018 | A8H0860-22 | Copper | 0.0130 | 0.00200 | 1.3 | ppm |
| 368-2211-N/A-001-B | Classroom Sink Bubbler - Classroom 103 | 8/30/2018 | 9/6/2018 | A8H0860-22 | Lead | 4.65 | 0.200 | 15 | ppb |

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.