

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Atkinson Elementary School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
234-DF-1145-A-006-A	Cafeteria	1/7/2022	1/18/2022	A2A0362-77	Lead	ND	0.2	15	ppb
234-DF-6199-A-006-A	Hallway (Classroom 103)	1/7/2022	1/18/2022	A2A0362-78	Lead	ND	0.2	15	ppb
234-DF-6201-A-006-A	Hallway (Classroom 115)	1/7/2022	1/18/2022	A2A0362-79	Lead	ND	0.2	15	ppb
234-DF-6195-A-006-A	Hallway (Gym)	1/7/2022	1/18/2022	A2A0362-80	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb