

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Beverly Cleary Fernwood K-8 - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
249-DF-1717-A-006-A	Hallway (Office)	1/7/2022	1/18/2022	A2A0362-69	Lead	ND	0.2	15	ppb
249-DF-9001-A-006-A	Hallway (Main Entrance)	1/7/2022	1/18/2022	A2A0362-70	Lead	ND	0.2	15	ppb
249-DF-1838-A-006-A	West Gymnasium	1/7/2022	1/18/2022	A2A0362-71	Lead	ND	0.2	15	ppb
249-DF-1705-A-006-A	Cafeteria	1/7/2022	1/18/2022	A2A0362-72	Lead	ND	0.2	15	ppb
249-DF-1845-A-006-A	Hallway (Gym)	1/7/2022	1/18/2022	A2A0362-73	Lead	ND	0.2	15	ppb
249-DF-1843-A-006-A	Hallway (Classroom 220)	1/7/2022	1/18/2022	A2A0362-74	Lead	1.22	0.2	15	ppb
249-DF-9002-A-006-A	Hallway (2nd FL SE)	1/7/2022	1/18/2022	A2A0362-75	Lead	1.24	0.2	15	ppb
249-DF-6177-A-006-A	Hallway (Classroom 2)	1/7/2022	1/18/2022	A2A0362-76	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb