

Portland Public Schools
Lead and Copper water Sampling Results
A (First Draw) Sample Data
Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-001A Boiler Room	6/27/2016 04:42	7/1/2016 08:33	10353865001	Copper	0.0	1.3	ppm
057-001A Boiler Room	6/27/2016 04:42	7/1/2016 08:33	10353865001	Lead	3	15	ppb
057-002A Room 14 - Sink	6/27/2016 04:50	7/1/2016 08:36	10353865003	Copper	0.4	1.3	ppm
057-002A Room 14 - Sink	6/27/2016 04:50	7/1/2016 08:36	10353865003	Lead	9	15	ppb
057-003A Room 14 - Drinking Fountain	6/27/2016 04:50	7/1/2016 08:37	10353865005	Copper	0.4	1.3	ppm
057-003A Room 14 - Drinking Fountain	6/27/2016 04:50	7/1/2016 08:37	10353865005	Lead	4	15	ppb
057-004A Room 13 - Sink	6/27/2016 04:51	7/1/2016 12:27	10353865007	Copper	1.1	1.3	ppm
057-004A Room 13 - Sink	6/27/2016 04:51	7/1/2016 08:39	10353865007	Lead	9	15	ppb
057-005A Room 13 - Drinking Fountain	6/27/2016 04:51	7/1/2016 08:40	10353865009	Copper	0.3	1.3	ppm
057-005A Room 13 - Drinking Fountain	6/27/2016 04:51	7/1/2016 08:40	10353865009	Lead	5	15	ppb
057-006A Room 11 - Sink	6/27/2016 04:55	7/1/2016 08:41	10353865011	Copper	0.3	1.3	ppm
057-006A Room 11 - Sink	6/27/2016 04:55	7/1/2016 08:41	10353865011	Lead	27	15	ppb
057-007A Restroom Next to Room 11-Sink	6/27/2016 04:57	7/1/2016 08:43	10353865013	Copper	0.2	1.3	ppm
057-007A Restroom Next to Room 11-Sink	6/27/2016 04:57	7/1/2016 08:43	10353865013	Lead	1	15	ppb
057-008A Room 9 - Sink	6/27/2016 04:59	7/1/2016 12:29	10353865015	Copper	0.5	1.3	ppm
057-008A Room 9 - Sink	6/27/2016 04:59	7/1/2016 08:44	10353865015	Lead	3	15	ppb
057-009A Boys Restroom Next to Room 9-Sink (Left)	6/27/2016 05:04	7/7/2016 14:08	10353865017	Copper	0.9	1.3	ppm
057-009A Boys Restroom Next to Room 9-Sink (Left)	6/27/2016 05:04	7/6/2016 20:19	10353865017	Lead	6	15	ppb
057-010A Boys Restroom Next to Room 9-Sink (Right)	6/27/2016 05:04	7/1/2016 08:50	10353865019	Copper	0.4	1.3	ppm
057-010A Boys Restroom Next to Room 9-Sink (Right)	6/27/2016 05:04	7/1/2016 08:50	10353865019	Lead	4	15	ppb
057-011A Room 12 - Sink	6/27/2016 05:08	7/1/2016 09:44	10353865021	Copper	0.3	1.3	ppm
057-011A Room 12 - Sink	6/27/2016 05:08	7/1/2016 09:44	10353865021	Lead	19	15	ppb
057-012A Room 12 - Drinking Fountain	6/27/2016 17:08	7/1/2016 12:32	10353865023	Copper	0.5	1.3	ppm
057-012A Room 12 - Drinking Fountain	6/27/2016 17:08	7/1/2016 09:48	10353865023	Lead	9	15	ppb
057-013A Girls Restroom-Sink (Left)	6/27/2016 17:10	7/1/2016 09:49	10353865025	Copper	0.2	1.3	ppm
057-013A Girls Restroom-Sink (Left)	6/27/2016 17:10	7/1/2016 09:49	10353865025	Lead	1	15	ppb
057-014A Girls Restroom-Sink (Right)	6/27/2016 17:10	7/1/2016 09:52	10353865027	Copper	0.2	1.3	ppm
057-014A Girls Restroom-Sink (Right)	6/27/2016 17:10	7/1/2016 09:52	10353865027	Lead	4	15	ppb
057-015A Room 7 - Sink (Left)	6/27/2016 17:14	7/7/2016 14:10	10353865029	Copper	0.6	1.3	ppm
057-015A Room 7 - Sink (Left)	6/27/2016 17:14	7/6/2016 20:20	10353865029	Lead	7	15	ppb

Portland Public Schools
Lead and Copper water Sampling Results
A (First Draw) Sample Data
Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-016A Room 7 - Sink (Right)	6/27/2016 17:14	7/7/2016 14:12	10353865031	Copper	1.9	1.3	ppm
057-016A Room 7 - Sink (Right)	6/27/2016 17:14	7/6/2016 20:26	10353865031	Lead	7	15	ppb
057-017A Room 7 - Drinking Fountain	6/27/2016 17:15	7/1/2016 12:33	10353865033	Copper	0.6	1.3	ppm
057-017A Room 7 - Drinking Fountain	6/27/2016 17:15	7/1/2016 09:54	10353865033	Lead	2	15	ppb
057-018A Room 10 - Sink	6/27/2016 17:18	7/1/2016 09:55	10353865035	Copper	0.3	1.3	ppm
057-018A Room 10 - Sink	6/27/2016 17:18	7/1/2016 09:55	10353865035	Lead	13	15	ppb
057-019A Room 10 - Drinking Fountain	6/27/2016 17:18	7/1/2016 12:38	10353865037	Copper	0.4	1.3	ppm
057-019A Room 10 - Drinking Fountain	6/27/2016 17:18	7/1/2016 09:56	10353865037	Lead	1	15	ppb
057-020A Room 5 - Sink	6/27/2016 17:21	7/1/2016 09:57	10353865039	Copper	0.3	1.3	ppm
057-020A Room 5 - Sink	6/27/2016 17:21	7/1/2016 09:57	10353865039	Lead	13	15	ppb
057-021A Room 5 - Drinking Fountain	6/27/2016 17:21	7/1/2016 09:59	10353865041	Copper	0.0	1.3	ppm
057-021A Room 5 - Drinking Fountain	6/27/2016 17:21	7/1/2016 09:59	10353865041	Lead	6	15	ppb
057-022A Room 8 - Sink	6/27/2016 17:25	7/1/2016 10:00	10353865043	Copper	0.3	1.3	ppm
057-022A Room 8 - Sink	6/27/2016 17:25	7/1/2016 10:00	10353865043	Lead	14	15	ppb
057-023A Room 8 - Drinking Fountain	6/27/2016 17:25	7/1/2016 12:40	10353865045	Copper	0.7	1.3	ppm
057-023A Room 8 - Drinking Fountain	6/27/2016 17:25	7/1/2016 10:06	10353865045	Lead	2	15	ppb
057-024A Boys Restroom Next to Room 8-Sink (Left)	6/27/2016 17:28	7/1/2016 10:08	10353865047	Copper	0.3	1.3	ppm
057-024A Boys Restroom Next to Room 8-Sink (Left)	6/27/2016 17:28	7/1/2016 10:08	10353865047	Lead	1	15	ppb
057-025A Boys Restroom Next to Room 8-Sink (Right)	6/27/2016 17:28	7/1/2016 10:09	10353865049	Copper	0.2	1.3	ppm
057-025A Boys Restroom Next to Room 8-Sink (Right)	6/27/2016 17:28	7/1/2016 10:09	10353865049	Lead	2	15	ppb
057-026A Girls Restroom-Sink (Left)	6/27/2016 17:31	7/1/2016 10:11	10353865051	Copper	0.3	1.3	ppm
057-026A Girls Restroom-Sink (Left)	6/27/2016 17:31	7/1/2016 10:11	10353865051	Lead	3	15	ppb
057-027A Girls Restroom-Sink (Right)	6/27/2016 17:31	7/1/2016 10:12	10353865053	Copper	0.4	1.3	ppm
057-027A Girls Restroom-Sink (Right)	6/27/2016 17:31	7/1/2016 10:12	10353865053	Lead	2	15	ppb
057-028A Room 3 - Sink	6/27/2016 17:35	7/1/2016 10:13	10353865055	Copper	0.3	1.3	ppm
057-028A Room 3 - Sink	6/27/2016 17:35	7/1/2016 10:13	10353865055	Lead	26	15	ppb
057-029A Room 3 - Drinking Fountain	6/27/2016 17:35	7/1/2016 12:41	10353865057	Copper	0.5	1.3	ppm
057-029A Room 3 - Drinking Fountain	6/27/2016 17:35	7/1/2016 10:15	10353865057	Lead	1	15	ppb
057-030A Room 6 - Sink	6/27/2016 17:38	7/1/2016 10:29	10353865059	Copper	0.3	1.3	ppm
057-030A Room 6 - Sink	6/27/2016 17:38	7/1/2016 10:29	10353865059	Lead	11	15	ppb

Portland Public Schools
Lead and Copper water Sampling Results
A (First Draw) Sample Data
Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-031A Room 6 - Drinking Fountain	6/27/2016 17:38	7/1/2016 12:44	10353865061	Copper	0.6	1.3	ppm
057-031A Room 6 - Drinking Fountain	6/27/2016 17:38	7/1/2016 10:31	10353865061	Lead	3	15	ppb
057-032A Custodial Closet Across from Room 6 - Sink Faucet	6/27/2016 17:40	7/1/2016 10:32	10353865063	Copper	0.4	1.3	ppm
057-032A Custodial Closet Across from Room 6 - Sink Faucet	6/27/2016 17:40	7/1/2016 10:32	10353865063	Lead	28	15	ppb
057-033A Hallway Fountain Outside Room 6	6/27/2016 17:40	7/1/2016 12:45	10353865065	Copper	0.5	1.3	ppm
057-033A Hallway Fountain Outside Room 6	6/27/2016 17:40	7/1/2016 10:33	10353865065	Lead	4	15	ppb
057-034A Office - Sink	6/27/2016 17:44	7/1/2016 10:35	10353865067	Copper	0.2	1.3	ppm
057-034A Office - Sink	6/27/2016 17:44	7/1/2016 10:35	10353865067	Lead	4	15	ppb
057-035A Room 4 - Sink	6/27/2016 17:48	7/1/2016 10:36	10353865069	Copper	0.3	1.3	ppm
057-035A Room 4 - Sink	6/27/2016 17:48	7/1/2016 10:36	10353865069	Lead	13	15	ppb
057-036A Room 4 - Drinking Fountain	6/27/2016 17:48	7/1/2016 12:46	10353865071	Copper	0.5	1.3	ppm
057-036A Room 4 - Drinking Fountain	6/27/2016 17:48	7/1/2016 10:38	10353865071	Lead	2	15	ppb
057-037A Room 1 - Sink (Left)	6/27/2016 17:51	7/1/2016 10:39	10353865073	Copper	0.1	1.3	ppm
057-037A Room 1 - Sink (Left)	6/27/2016 17:51	7/1/2016 10:39	10353865073	Lead	3	15	ppb
057-038A Room 1 - Sink (Right)	6/27/2016 17:51	7/1/2016 10:43	10353865075	Copper	0.2	1.3	ppm
057-038A Room 1 - Sink (Right)	6/27/2016 17:51	7/1/2016 10:43	10353865075	Lead	4	15	ppb
057-039A Room 1 - Drinking Fountain	6/27/2016 17:52	7/1/2016 12:48	10353865077	Copper	0.5	1.3	ppm
057-039A Room 1 - Drinking Fountain	6/27/2016 17:52	7/1/2016 10:45	10353865077	Lead	2	15	ppb
057-040A Custodial Closet Outside Room 2 - Sink Faucet	6/27/2016 17:54	7/1/2016 10:48	10353865079	Copper	0.1	1.3	ppm
057-040A Custodial Closet Outside Room 2 - Sink Faucet	6/27/2016 17:54	7/1/2016 10:48	10353865079	Lead	2	15	ppb
057-041A Room 2 - Sink (Right)	6/27/2016 17:56	7/1/2016 10:49	10353865081	Copper	0.1	1.3	ppm
057-041A Room 2 - Sink (Right)	6/27/2016 17:56	7/1/2016 10:49	10353865081	Lead	1	15	ppb
057-042A Room 2 - Sink (Left)	6/27/2016 17:56	7/6/2016 20:27	10353865083	Copper	0.3	1.3	ppm
057-042A Room 2 - Sink (Left)	6/27/2016 17:56	7/6/2016 20:27	10353865083	Lead	7	15	ppb
057-043A Drinking Fountain Outside Room 13	6/27/2016 17:59	7/1/2016 10:50	10353865085	Copper	0.0	1.3	ppm
057-043A Drinking Fountain Outside Room 13	6/27/2016 17:59	7/1/2016 10:50	10353865085	Lead	9	15	ppb
057-044A Restroom 37 - Sink Faucet	6/27/2016 18:04	7/1/2016 10:52	10353865087	Copper	0.1	1.3	ppm
057-044A Restroom 37 - Sink Faucet	6/27/2016 18:04	7/1/2016 10:52	10353865087	Lead	4	15	ppb
057-095A Room 2 - Drinking Fountain	6/27/2016 19:59	7/7/2016 10:05	10353865189	Copper	0.6	1.3	ppm
057-095A Room 2 - Drinking Fountain	6/27/2016 19:59	7/6/2016 20:08	10353865189	Lead	1	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

Portland Public Schools
Lead and Copper water Sampling Results
A (First Draw) Sample Data
Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-45A Drinking Fountain Outside Room 37	6/27/2016 18:05	7/1/2016 10:53	10353865089	Copper	0.3	1.3	ppm
057-45A Drinking Fountain Outside Room 37	6/27/2016 18:05	7/1/2016 10:53	10353865089	Lead	3	15	ppb
057-46A Room 15 - Sink Faucet	6/27/2016 18:08	7/7/2016 14:13	10353865091	Copper	1.0	1.3	ppm
057-46A Room 15 - Sink Faucet	6/27/2016 18:08	7/6/2016 20:28	10353865091	Lead	20	15	ppb
057-47A Room 15 - Drinking Fountain	6/27/2016 18:08	7/1/2016 10:54	10353865093	Copper	0.1	1.3	ppm
057-47A Room 15 - Drinking Fountain	6/27/2016 18:08	7/1/2016 10:54	10353865093	Lead	1	15	ppb
057-48A Women's Restroom Across from Room 15 Sink Faucet	6/27/2016 18:10	7/1/2016 10:56	10353865095	Copper	0.3	1.3	ppm
057-48A Women's Restroom Across from Room 15 Sink Faucet	6/27/2016 18:10	7/1/2016 10:56	10353865095	Lead	25	15	ppb
057-49A Room 16 - Sink Faucet	6/27/2016 18:12	7/1/2016 11:02	10353865097	Copper	0.2	1.3	ppm
057-49A Room 16 - Sink Faucet	6/27/2016 18:12	7/1/2016 11:02	10353865097	Lead	3	15	ppb
057-50A Room 16 - Drinking Fountain	6/27/2016 18:12	7/1/2016 11:04	10353865099	Copper	0.1	1.3	ppm
057-50A Room 16 - Drinking Fountain	6/27/2016 18:12	7/1/2016 11:04	10353865099	Lead	3	15	ppb
057-51A Room 33 Custodian Closet - Sink Faucet	6/27/2016 18:15	7/5/2016 15:50	10353865101	Copper	0.1	1.3	ppm
057-51A Room 33 Custodian Closet - Sink Faucet	6/27/2016 18:15	7/5/2016 15:50	10353865101	Lead	2	15	ppb
057-52A Kitchen Dish Wash Sink Faucet	6/27/2016 18:17	7/5/2016 15:55	10353865103	Copper	0.2	1.3	ppm
057-52A Kitchen Dish Wash Sink Faucet	6/27/2016 18:17	7/5/2016 15:55	10353865103	Lead	1	15	ppb
057-53A Kitchen Food Preparation Station	6/27/2016 18:17	7/6/2016 11:24	10353865105	Copper	0.2	1.3	ppm
057-53A Kitchen Food Preparation Station	6/27/2016 18:17	7/6/2016 11:24	10353865105	Lead	0	15	ppb
057-54A Kitchen Sink Faucet	6/27/2016 18:19	7/5/2016 16:03	10353865107	Copper	0.3	1.3	ppm
057-54A Kitchen Sink Faucet	6/27/2016 18:19	7/5/2016 16:03	10353865107	Lead	2	15	ppb
057-55A Kitchen Bathroom Sink Faucet	6/27/2016 18:23	7/5/2016 16:05	10353865109	Copper	0.4	1.3	ppm
057-55A Kitchen Bathroom Sink Faucet	6/27/2016 18:23	7/5/2016 16:05	10353865109	Lead	2	15	ppb
057-56A Kitchen Custodial Closet Sink Faucet	6/27/2016 18:25	7/5/2016 16:06	10353865111	Copper	0.0	1.3	ppm
057-56A Kitchen Custodial Closet Sink Faucet	6/27/2016 18:25	7/5/2016 16:06	10353865111	Lead	10	15	ppb
057-57A Cafeteria Drinking Fountain	6/27/2016 18:27	7/5/2016 16:07	10353865113	Copper	0.0	1.3	ppm
057-57A Cafeteria Drinking Fountain	6/27/2016 18:27	7/5/2016 16:07	10353865113	Lead	2	15	ppb
057-58A Room 17 - Sink Faucet	6/27/2016 18:30	7/7/2016 16:52	10353865115	Copper	0.2	1.3	ppm
057-58A Room 17 - Sink Faucet	6/27/2016 18:30	7/7/2016 16:52	10353865115	Lead	5	15	ppb
057-59A Room 17 - Drinking Fountain	6/27/2016 18:30	7/5/2016 16:09	10353865117	Copper	0.0	1.3	ppm
057-59A Room 17 - Drinking Fountain	6/27/2016 18:30	7/5/2016 16:09	10353865117	Lead	0	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

Portland Public Schools
Lead and Copper water Sampling Results
A (First Draw) Sample Data
Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-60A Gymnasium Room 30 - Drinking Fountain	6/27/2016 18:32	7/5/2016 16:10	10353865119	Copper	0.4	1.3	ppm
057-60A Gymnasium Room 30 - Drinking Fountain	6/27/2016 18:32	7/5/2016 16:10	10353865119	Lead	4	15	ppb
057-61A Room 18/Library - Sink Faucet (1)	6/27/2016 18:35	7/5/2016 16:11	10353865121	Copper	0.2	1.3	ppm
057-61A Room 18/Library - Sink Faucet (1)	6/27/2016 18:35	7/5/2016 16:11	10353865121	Lead	3	15	ppb
057-62A Room 18/Library - Drinking Fountain (1)	6/27/2016 18:35	7/5/2016 16:12	10353865123	Copper	0.0	1.3	ppm
057-62A Room 18/Library - Drinking Fountain (1)	6/27/2016 18:35	7/5/2016 16:12	10353865123	Lead	1	15	ppb
057-63A Room 18/Library - Sink Faucet (2)	6/27/2016 18:37	7/6/2016 11:26	10353865125	Copper	0.8	1.3	ppm
057-63A Room 18/Library - Sink Faucet (2)	6/27/2016 18:37	7/5/2016 16:14	10353865125	Lead	45	15	ppb
057-64A Room 18/Library - Drinking Fountain (2)	6/27/2016 18:37	7/5/2016 16:19	10353865127	Copper	0.0	1.3	ppm
057-64A Room 18/Library - Drinking Fountain (2)	6/27/2016 18:37	7/5/2016 16:19	10353865127	Lead	0	15	ppb
057-65A Girls Restroom Sink Faucet (1)	6/27/2016 18:40	7/5/2016 16:21	10353865129	Copper	0.3	1.3	ppm
057-65A Girls Restroom Sink Faucet (1)	6/27/2016 18:40	7/5/2016 16:21	10353865129	Lead	3	15	ppb
057-66A Girls Restroom Sink Faucet (2)	6/27/2016 18:40	7/5/2016 16:22	10353865131	Copper	0.3	1.3	ppm
057-66A Girls Restroom Sink Faucet (2)	6/27/2016 18:40	7/5/2016 16:22	10353865131	Lead	2	15	ppb
057-67A Custodial Closet/Room 27 - Sink Faucet	6/27/2016 18:43	7/5/2016 16:23	10353865133	Copper	0.1	1.3	ppm
057-67A Custodial Closet/Room 27 - Sink Faucet	6/27/2016 18:43	7/5/2016 16:23	10353865133	Lead	1	15	ppb
057-68A Drinking Fountain in Hall Between Rooms 27 & 26	6/27/2016 18:46	7/5/2016 16:25	10353865135	Copper	0.3	1.3	ppm
057-68A Drinking Fountain in Hall Between Rooms 27 & 26	6/27/2016 18:46	7/5/2016 16:25	10353865135	Lead	3	15	ppb
057-69A Boys Restroom Sink Faucet (1)	6/27/2016 18:49	7/5/2016 16:26	10353865137	Copper	0.2	1.3	ppm
057-69A Boys Restroom Sink Faucet (1)	6/27/2016 18:49	7/5/2016 16:26	10353865137	Lead	1	15	ppb
057-70A Boys Restroom Sink Faucet (2)	6/27/2016 18:49	7/5/2016 16:27	10353865139	Copper	0.2	1.3	ppm
057-70A Boys Restroom Sink Faucet (2)	6/27/2016 18:49	7/5/2016 16:27	10353865139	Lead	1	15	ppb
057-71A Room 20 - Sink Faucet	6/27/2016 18:52	7/6/2016 19:33	10353865141	Copper	0.2	1.3	ppm
057-71A Room 20 - Sink Faucet	6/27/2016 18:52	7/6/2016 19:33	10353865141	Lead	2	15	ppb
057-72A Room 20 - Drinking Fountain	6/27/2016 18:52	7/6/2016 19:38	10353865143	Copper	0.3	1.3	ppm
057-72A Room 20 - Drinking Fountain	6/27/2016 18:52	7/6/2016 19:38	10353865143	Lead	5	15	ppb
057-73A Room 21 - Sink Faucet	6/27/2016 18:55	7/8/2016 13:14	10353865145	Copper	0.2	1.3	ppm
057-73A Room 21 - Sink Faucet	6/27/2016 18:55	7/8/2016 13:14	10353865145	Lead	5	15	ppb
057-75A Room 24 - Sink Faucet	6/27/2016 18:58	7/6/2016 19:40	10353865149	Copper	0.3	1.3	ppm
057-75A Room 24 - Sink Faucet	6/27/2016 18:58	7/6/2016 19:40	10353865149	Lead	20	15	ppb

Portland Public Schools
Lead and Copper water Sampling Results
A (First Draw) Sample Data
Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-76A Room 24 - Drinking Fountain	6/27/2016 19:00	7/6/2016 19:41	10353865151	Copper	0.0	1.3	ppm
057-76A Room 24 - Drinking Fountain	6/27/2016 19:00	7/6/2016 19:41	10353865151	Lead	1	15	ppb
057-77A Room 22 - Sink Faucet	6/27/2016 19:03	7/7/2016 14:27	10353865153	Copper	0.5	1.3	ppm
057-77A Room 22 - Sink Faucet	6/27/2016 19:03	7/6/2016 19:42	10353865153	Lead	5	15	ppb
057-78A Room 22 - Drinking Fountain	6/27/2016 19:03	7/7/2016 14:29	10353865155	Copper	0.6	1.3	ppm
057-78A Room 22 - Drinking Fountain	6/27/2016 19:03	7/6/2016 19:47	10353865155	Lead	2	15	ppb
057-79A Room 23 - Sink Faucet	6/27/2016 19:05	7/6/2016 19:48	10353865157	Copper	0.2	1.3	ppm
057-79A Room 23 - Sink Faucet	6/27/2016 19:05	7/6/2016 19:48	10353865157	Lead	7	15	ppb
057-80A Room 23 - Drinking Fountain	6/27/2016 19:05	7/6/2016 19:49	10353865159	Copper	0.4	1.3	ppm
057-80A Room 23 - Drinking Fountain	6/27/2016 19:05	7/6/2016 19:49	10353865159	Lead	1	15	ppb
057-81A Spigot Outside East Doors	6/27/2016 19:15	7/6/2016 19:51	10353865161	Copper	0.1	1.3	ppm
057-81A Spigot Outside East Doors	6/27/2016 19:15	7/6/2016 19:51	10353865161	Lead	1	15	ppb
057-82A Spigot Outside Room 21 West	6/27/2016 19:17	7/6/2016 19:52	10353865163	Copper	0.3	1.3	ppm
057-82A Spigot Outside Room 21 West	6/27/2016 19:17	7/6/2016 19:52	10353865163	Lead	6	15	ppb
057-83A Spigot Outside Shelter West	6/27/2016 19:19	7/6/2016 19:53	10353865165	Copper	0.1	1.3	ppm
057-83A Spigot Outside Shelter West	6/27/2016 19:19	7/6/2016 19:53	10353865165	Lead	24	15	ppb
057-84A Spigot Outside North Doors	6/27/2016 19:24	7/6/2016 20:00	10353865167	Copper	0.2	1.3	ppm
057-84A Spigot Outside North Doors	6/27/2016 19:24	7/6/2016 20:00	10353865167	Lead	4	15	ppb
057-85A Spigot Outside Room 24 East	6/27/2016 19:27	7/6/2016 20:02	10353865169	Copper	0.0	1.3	ppm
057-85A Spigot Outside Room 24 East	6/27/2016 19:27	7/6/2016 20:02	10353865169	Lead	5	15	ppb
057-86A Spigot Outside Gymnasium Wall Northeast	6/27/2016 19:29	7/6/2016 20:06	10353865171	Copper	0.2	1.3	ppm
057-86A Spigot Outside Gymnasium Wall Northeast	6/27/2016 19:29	7/6/2016 20:06	10353865171	Lead	11	15	ppb
057-87A Spigot Outside Gymnasium West Doors	6/27/2016 19:32	7/6/2016 20:07	10353865173	Copper	0.4	1.3	ppm
057-87A Spigot Outside Gymnasium West Doors	6/27/2016 19:32	7/6/2016 20:07	10353865173	Lead	4	15	ppb
057-88A Spigot Outside Room Facility Room	6/27/2016 19:35	7/6/2016 20:09	10353865175	Copper	0.1	1.3	ppm
057-88A Spigot Outside Room Facility Room	6/27/2016 19:35	7/6/2016 20:09	10353865175	Lead	12	15	ppb
057-89A Spigot Outside Room 12	6/27/2016 19:38	7/6/2016 20:10	10353865177	Copper	0.1	1.3	ppm
057-89A Spigot Outside Room 12	6/27/2016 19:38	7/6/2016 20:10	10353865177	Lead	7	15	ppb
057-90A Spigot Outside Room 4	6/27/2016 19:41	7/6/2016 20:12	10353865179	Copper	0.2	1.3	ppm
057-90A Spigot Outside Room 4	6/27/2016 19:41	7/6/2016 20:12	10353865179	Lead	12	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

Portland Public Schools
 Lead and Copper water Sampling Results
 A (First Draw) Sample Data
 Lewis Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
057-91A Spigot Outside Rooms 1 & 2	6/27/2016 19:43	7/6/2016 20:01	10353865181	Copper	0.1	1.3	ppm
057-91A Spigot Outside Rooms 1 & 2	6/27/2016 19:43	7/6/2016 20:01	10353865181	Lead	10	15	ppb
057-92A Spigot Left of Main Entrance	6/27/2016 19:46	7/7/2016 10:46	10353865183	Copper	0.0	1.3	ppm
057-92A Spigot Left of Main Entrance	6/27/2016 19:46	7/7/2016 10:46	10353865183	Lead	5	15	ppb
057-93A Spigot Outside Room 5/7	6/27/2016 19:49	7/8/2016 07:29	10353865185	Copper	0.5	1.3	ppm
057-93A Spigot Outside Room 5/7	6/27/2016 19:49	7/7/2016 17:02	10353865185	Lead	7	15	ppb
057-94A Spigot Outside Boiler Room/Facilities Room	6/27/2016 19:57	7/8/2016 13:15	10353865187	Copper	0.0	1.3	ppm
057-94A Spigot Outside Boiler Room/Facilities Room	6/27/2016 19:57	7/8/2016 13:15	10353865187	Lead	0	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.