

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Woodstock Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
095-01A Room 5 Sink Faucet	6/26/2016 13:59	7/7/2016 12:16	10353860001	Copper	0.3	1.3	ppm
095-01A Room 5 Sink Faucet	6/26/2016 13:59	7/7/2016 12:16	10353860001	Lead	6	15	ppb
095-02A Boiler Room Sink Faucet	6/26/2016 14:01	7/7/2016 12:22	10353860003	Copper	0.1	1.3	ppm
095-02A Boiler Room Sink Faucet	6/26/2016 14:01	7/7/2016 12:22	10353860003	Lead	20	15	ppb
095-03A Fan Room Sink Faucet	6/26/2016 14:02	7/7/2016 12:23	10353860005	Copper	0.1	1.3	ppm
095-03A Fan Room Sink Faucet	6/26/2016 14:02	7/7/2016 12:23	10353860005	Lead	5	15	ppb
095-04A Gymnasium Drinking Fountain	6/26/2016 14:50	7/7/2016 12:24	10353860007	Copper	0.0	1.3	ppm
095-04A Gymnasium Drinking Fountain	6/26/2016 14:50		10353860007	Lead	2	15	ppb
095-05A Playroom Hall Drinking Fountain	6/26/2016 15:39	7/7/2016 12:26	10353860009	Copper	0.1	1.3	ppm
095-05A Playroom Hall Drinking Fountain	6/26/2016 15:39	7/7/2016 12:26	10353860009	Lead	9	15	ppb
095-06A Playroom Hall Drinking Fountain	6/26/2016 15:41	7/7/2016 12:27	10353860011	Copper	0.0	1.3	ppm
095-06A Playroom Hall Drinking Fountain	6/26/2016 15:41	7/7/2016 12:27	10353860011	Lead	3	15	ppb
095-07A Girls Locker Room Sink Faucet	6/26/2016 14:54	7/7/2016 12:28	10353860013	Copper	0.0	1.3	ppm
095-07A Girls Locker Room Sink Faucet	6/26/2016 14:54	7/7/2016 12:28	10353860013	Lead	47	15	ppb
095-08A Girls Locker Room Spigot	6/26/2016 14:59	7/7/2016 08:30	10353860015	Copper	0.3	1.3	ppm
095-08A Girls Locker Room Spigot	6/26/2016 14:59	7/7/2016 08:30	10353860015	Lead	42	15	ppb
095-09A Boys Locker Room Spigot	6/26/2016 15:04	7/7/2016 14:30	10353860017	Copper	0.7	1.3	ppm
095-09A Boys Locker Room Spigot	6/26/2016 15:04	7/7/2016 08:31	10353860017	Lead	408	15	ppb
095-10A Boys Restroom Sink Faucet (1)	6/26/2016 15:38	7/7/2016 12:33	10353860019	Copper	0.1	1.3	ppm
095-10A Boys Restroom Sink Faucet (1)	6/26/2016 15:38	7/7/2016 12:33	10353860019	Lead	16	15	ppb
095-11A Boys Restroom Sink Faucet (2)	6/26/2016 15:36	7/7/2016 12:34	10353860021	Copper	0.1	1.3	ppm
095-11A Boys Restroom Sink Faucet (2)	6/26/2016 15:36	7/7/2016 12:34	10353860021	Lead	16	15	ppb
095-12A Boys Restroom Spigot (1)	6/26/2016 15:40	7/7/2016 08:32	10353860023	Copper	0.1	1.3	ppm
095-12A Boys Restroom Spigot (1)	6/26/2016 15:40	7/7/2016 08:32	10353860023	Lead	69	15	ppb
095-13A Boys Restroom Spigot (2)	6/26/2016 15:42	7/7/2016 14:31	10353860025	Copper	1.9	1.3	ppm
095-13A Boys Restroom Spigot (2)	6/26/2016 15:42	7/7/2016 08:36	10353860025	Lead	52	15	ppb
095-14A Boys Restroom Sink Faucet (1)	6/26/2016 15:35	7/7/2016 12:35	10353860027	Copper	0.1	1.3	ppm
095-14A Boys Restroom Sink Faucet (1)	6/26/2016 15:35	7/7/2016 12:35	10353860027	Lead	13	15	ppb
095-15A Boys Restroom Sink Faucet (2)	6/26/2016 15:33	7/7/2016 08:37	10353860029	Copper	0.2	1.3	ppm
095-15A Boys Restroom Sink Faucet (2)	6/26/2016 15:33	7/7/2016 08:37	10353860029	Lead	23	15	ppb
095-16A Room 16 Sink Faucet	6/26/2016 15:43	7/7/2016 12:37	10353860031	Copper	0.4	1.3	ppm
095-16A Room 16 Sink Faucet	6/26/2016 15:43	7/7/2016 12:37	10353860031	Lead	25	15	ppb
095-17A Room 17 Sink Faucet (1)	6/26/2016 15:46	7/7/2016 12:39	10353860033	Copper	0.1	1.3	ppm
095-17A Room 17 Sink Faucet (1)	6/26/2016 15:46	7/7/2016 12:39	10353860033	Lead	23	15	ppb
095-18A Room 17 Sink Faucet (2)	6/26/2016 15:45	7/7/2016 08:38	10353860035	Copper	0.1	1.3	ppm
095-18A Room 17 Sink Faucet (2)	6/26/2016 15:45	7/7/2016 08:38	10353860035	Lead	11	15	ppb
095-19A Room 18 Sink Faucet	6/26/2016 15:47	7/7/2016 08:39	10353860037	Copper	0.5	1.3	ppm
095-19A Room 18 Sink Faucet	6/26/2016 15:47	7/7/2016 08:39	10353860037	Lead	39	15	ppb
095-20A Room 18 Drinking Fountain	6/26/2016 15:48	7/7/2016 15:47	10353860039	Copper	0.4	1.3	ppm
095-20A Room 18 Drinking Fountain	6/26/2016 15:48	7/7/2016 12:41	10353860039	Lead	5	15	ppb
095-21A Boys Restroom Sink Faucet (1)	6/26/2016 15:58	7/7/2016 08:41	10353860041	Copper	0.1	1.3	ppm
095-21A Boys Restroom Sink Faucet (1)	6/26/2016 15:58	7/7/2016 08:41	10353860041	Lead	12	15	ppb
095-22A Boys Restroom Sink Faucet (2)	6/26/2016 15:59	7/7/2016 12:59	10353860043	Copper	0.1	1.3	ppm

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Woodstock Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
095-22A Boys Restroom Sink Faucet (2)	6/26/2016 15:59	7/7/2016 12:59	10353860043	Lead	15.4	15	ppb
095-23A Boys Restroom Spigot	6/26/2016 16:01	7/7/2016 14:32	10353860045	Copper	0.8	1.3	ppm
095-23A Boys Restroom Spigot	6/26/2016 16:01	7/7/2016 08:42	10353860045	Lead	45	15	ppb
095-24A Girls Restroom Sink Faucet (1)	6/26/2016 15:48	7/7/2016 13:07	10353860047	Copper	0.1	1.3	ppm
095-24A Girls Restroom Sink Faucet (1)	6/26/2016 15:48	7/7/2016 13:07	10353860047	Lead	17	15	ppb
095-25A Girls Restroom Sink Faucet (2)	6/26/2016 15:52	7/7/2016 08:43	10353860049	Copper	0.3	1.3	ppm
095-25A Girls Restroom Sink Faucet (2)	6/26/2016 15:52	7/7/2016 08:43	10353860049	Lead	22	15	ppb
095-26A Girls Restroom Spigot	6/26/2016 15:50	7/7/2016 14:33	10353860051	Copper	1.5	1.3	ppm
095-26A Girls Restroom Spigot	6/26/2016 15:50	7/7/2016 08:46	10353860051	Lead	77	15	ppb
095-27A Hallway Drinking Fountain (1)	6/26/2016 15:56	7/7/2016 13:09	10353860053	Copper	0.1	1.3	ppm
095-27A Hallway Drinking Fountain (1)	6/26/2016 15:56	7/7/2016 13:09	10353860053	Lead	4	15	ppb
095-28A Hallway Drinking Fountain (2)	6/26/2016 15:31	7/7/2016 13:10	10353860055	Copper	0.2	1.3	ppm
095-28A Hallway Drinking Fountain (2)	6/26/2016 15:31	7/7/2016 13:10	10353860055	Lead	4	15	ppb
095-29A Staff Unisex Restroom Sink	6/26/2016 15:29	7/7/2016 08:47	10353860057	Copper	0.1	1.3	ppm
095-29A Staff Unisex Restroom Sink	6/26/2016 15:29	7/7/2016 08:47	10353860057	Lead	19	15	ppb
095-30A Womens Staff Restroom Sink	6/26/2016 15:31	7/7/2016 13:12	10353860059	Copper	0.0	1.3	ppm
095-30A Womens Staff Restroom Sink	6/26/2016 15:31	7/7/2016 13:12	10353860059	Lead	8	15	ppb
095-31A Mens Restroom Sink Faucet	6/26/2016 15:33	7/7/2016 13:13	10353860061	Copper	0.0	1.3	ppm
095-31A Mens Restroom Sink Faucet	6/26/2016 15:33	7/7/2016 13:13	10353860061	Lead	12	15	ppb
095-32A Faculty Cafeteria Sink Faucet (1)	6/26/2016 15:37	7/7/2016 13:14	10353860063	Copper	0.1	1.3	ppm
095-32A Faculty Cafeteria Sink Faucet (1)	6/26/2016 15:37	7/7/2016 13:14	10353860063	Lead	31	15	ppb
095-33A Faculty Cafeteria Sink Faucet (2)	6/26/2016 15:35	7/7/2016 13:16	10353860065	Copper	0.1	1.3	ppm
095-33A Faculty Cafeteria Sink Faucet (2)	6/26/2016 15:35	7/7/2016 13:16	10353860065	Lead	45	15	ppb
095-34A Hallway Drinking Fountain	6/26/2016 15:27	7/7/2016 13:17	10353860067	Copper	0.1	1.3	ppm
095-34A Hallway Drinking Fountain	6/26/2016 15:27	7/7/2016 13:17	10353860067	Lead	9	15	ppb
095-35A Room 8 Sink Faucet	6/26/2016 15:12	7/7/2016 15:55	10353860069	Copper	0.5	1.3	ppm
095-35A Room 8 Sink Faucet	6/26/2016 15:12	7/7/2016 13:19	10353860069	Lead	9	15	ppb
095-36A Room 8 Drinking Fountain	6/26/2016 15:10	7/7/2016 15:56	10353860071	Copper	0.8	1.3	ppm
095-36A Room 8 Drinking Fountain	6/26/2016 15:10	7/7/2016 13:20	10353860071	Lead	14	15	ppb
095-37A Hallway Drinking Fountain	6/26/2016 15:18	7/7/2016 14:16	10353860073	Copper	0.1	1.3	ppm
095-37A Hallway Drinking Fountain	6/26/2016 15:18	7/7/2016 14:16	10353860073	Lead	7	15	ppb
095-38A Room 9 Sink Faucet	6/26/2016 15:22	7/7/2016 14:17	10353860075	Copper	0.3	1.3	ppm
095-38A Room 9 Sink Faucet	6/26/2016 15:22	7/7/2016 14:17	10353860075	Lead	7	15	ppb
095-39A Room 9 Drinking Fountain	6/26/2016 15:24	7/7/2016 14:19	10353860077	Copper	0.3	1.3	ppm
095-39A Room 9 Drinking Fountain	6/26/2016 15:24	7/7/2016 14:19	10353860077	Lead	3	15	ppb
095-40A Room 10 Sink Faucet	6/26/2016 15:18	7/7/2016 14:20	10353860079	Copper	0.3	1.3	ppm
095-40A Room 10 Sink Faucet	6/26/2016 15:18	7/7/2016 14:20	10353860079	Lead	7	15	ppb
095-41A Room 10 Drinking Fountain	6/26/2016 15:13	7/7/2016 14:23	10353860081	Copper	0.2	1.3	ppm
095-41A Room 10 Drinking Fountain	6/26/2016 15:13	7/7/2016 14:23	10353860081	Lead	2	15	ppb
095-42A Girls Restroom Sink Faucet (Left)	6/26/2016 15:21	7/7/2016 14:24	10353860083	Copper	0.0	1.3	ppm
095-42A Girls Restroom Sink Faucet (Left)	6/26/2016 15:21	7/7/2016 14:24	10353860083	Lead	3	15	ppb
095-43A Girls Restroom Sink Faucet	6/26/2016 15:22	7/7/2016 14:25	10353860085	Copper	0.0	1.3	ppm
095-43A Girls Restroom Sink Faucet	6/26/2016 15:22	7/7/2016 14:25	10353860085	Lead	3	15	ppb

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Woodstock Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
095-44A Girls Restroom Spigot	6/26/2016 15:23	7/7/2016 08:51	10353860087	Copper	0.2	1.3	ppm
<b>095-44A Girls Restroom Spigot</b>	<b>6/26/2016 15:23</b>	<b>7/7/2016 08:51</b>	<b>10353860087</b>	<b>Lead</b>	<b>50</b>	<b>15</b>	<b>ppb</b>
095-45A Boys Restroom Sink Faucet (Left)	6/26/2016 15:11	7/7/2016 08:52	10353860089	Copper	0.1	1.3	ppm
095-45A Boys Restroom Sink Faucet (Left)	6/26/2016 15:11	7/7/2016 08:52	10353860089	Lead	9	15	ppb
095-46A Boys Restroom Sink Faucet	6/26/2016 15:13	7/7/2016 14:27	10353860091	Copper	0.0	1.3	ppm
095-46A Boys Restroom Sink Faucet	6/26/2016 15:13	7/7/2016 14:27	10353860091	Lead	3	15	ppb
095-47A Boys Restroom Spigot	6/26/2016 15:16	7/7/2016 08:53	10353860093	Copper	0.2	1.3	ppm
095-47A Boys Restroom Spigot	6/26/2016 15:16	7/7/2016 08:53	10353860093	Lead	7	15	ppb
095-48A Library Sink Faucet	6/26/2016 15:11	7/7/2016 15:06	10353860095	Copper	0.1	1.3	ppm
<b>095-48A Library Sink Faucet</b>	<b>6/26/2016 15:11</b>	<b>7/7/2016 15:06</b>	<b>10353860095</b>	<b>Lead</b>	<b>18</b>	<b>15</b>	<b>ppb</b>
095-49A Custodial Sink Faucet	6/26/2016 15:26	7/7/2016 15:08	10353860097	Copper	0.2	1.3	ppm
095-49A Custodial Sink Faucet	6/26/2016 15:26	7/7/2016 15:08	10353860097	Lead	8	15	ppb
095-50A Room 14 Sink Faucet	6/26/2016 15:29	7/7/2016 15:09	10353860099	Copper	0.1	1.3	ppm
<b>095-50A Room 14 Sink Faucet</b>	<b>6/26/2016 15:29</b>	<b>7/7/2016 15:09</b>	<b>10353860099</b>	<b>Lead</b>	<b>76</b>	<b>15</b>	<b>ppb</b>
095-51A Girls Restroom Sink Faucet (1)	6/26/2016 15:01	7/7/2016 15:11	10353860101	Copper	0.1	1.3	ppm
095-51A Girls Restroom Sink Faucet (1)	6/26/2016 15:01	7/7/2016 15:11	10353860101	Lead	10	15	ppb
095-52A Girls Restroom Sink Faucet (2)	6/26/2016 15:03	7/7/2016 08:54	10353860103	Copper	0.2	1.3	ppm
<b>095-52A Girls Restroom Sink Faucet (2)</b>	<b>6/26/2016 15:03</b>	<b>7/7/2016 08:54</b>	<b>10353860103</b>	<b>Lead</b>	<b>27</b>	<b>15</b>	<b>ppb</b>
095-53A Girls Restroom Sink Faucet (3)	6/26/2016 15:03	7/7/2016 08:55	10353860105	Copper	0.2	1.3	ppm
095-53A Girls Restroom Sink Faucet (3)	6/26/2016 15:03	7/7/2016 08:55	10353860105	Lead	14.6	15	ppb
095-54A Girls Restroom Spigot	6/26/2016 15:07	7/7/2016 08:56	10353860107	Copper	0.3	1.3	ppm
<b>095-54A Girls Restroom Spigot</b>	<b>6/26/2016 15:07</b>	<b>7/7/2016 08:56</b>	<b>10353860107</b>	<b>Lead</b>	<b>38</b>	<b>15</b>	<b>ppb</b>
095-55A Girls Restroom Sink Faucet (1)	6/26/2016 15:03	7/7/2016 15:12	10353860109	Copper	0.1	1.3	ppm
095-55A Girls Restroom Sink Faucet (1)	6/26/2016 15:03	7/7/2016 15:12	10353860109	Lead	5	15	ppb
095-56A Girls Restroom Sink Faucet (2)	6/26/2016 15:04	7/7/2016 17:38	10353860111	Copper	0.0	1.3	ppm
095-56A Girls Restroom Sink Faucet (2)	6/26/2016 15:04	7/7/2016 17:38	10353860111	Lead	3	15	ppb
095-57A Girls Restroom Sink Faucet (3)	6/26/2016 15:06	7/7/2016 15:13	10353860113	Copper	0.1	1.3	ppm
<b>095-57A Girls Restroom Sink Faucet (3)</b>	<b>6/26/2016 15:06</b>	<b>7/7/2016 15:13</b>	<b>10353860113</b>	<b>Lead</b>	<b>20</b>	<b>15</b>	<b>ppb</b>
095-58A Hallway Drinking Fountain (1)	6/26/2016 14:55	7/7/2016 15:37	10353860115	Copper	0.0	1.3	ppm
095-58A Hallway Drinking Fountain (1)	6/26/2016 14:55	7/7/2016 15:37	10353860115	Lead	8	15	ppb
095-59A Hallway Drinking Fountain (2)	6/26/2016 14:57	7/7/2016 15:38	10353860117	Copper	0.0	1.3	ppm
095-59A Hallway Drinking Fountain (2)	6/26/2016 14:57	7/7/2016 15:38	10353860117	Lead	4	15	ppb
095-60A Hallway Drinking Fountain (3)	6/26/2016 14:59	7/8/2016 07:54	10353860119	Copper	0.0	1.3	ppm
095-60A Hallway Drinking Fountain (3)	6/26/2016 14:59	7/8/2016 07:54	10353860119	Lead	1	15	ppb
095-61A Kitchen Sink Faucet (1)	6/26/2016 14:32	7/7/2016 14:34	10353860121	Copper	0.2	1.3	ppm
095-61A Kitchen Sink Faucet (1)	6/26/2016 14:32	7/7/2016 14:34	10353860121	Lead	8	15	ppb
095-62A Kitchen Sink Faucet (2)	6/26/2016 14:31	7/7/2016 14:39	10353860123	Copper	0.2	1.3	ppm
<b>095-62A Kitchen Sink Faucet (2)</b>	<b>6/26/2016 14:31</b>	<b>7/7/2016 14:39</b>	<b>10353860123</b>	<b>Lead</b>	<b>20</b>	<b>15</b>	<b>ppb</b>
095-63A Kitchen Sink Faucet (3)	6/26/2016 14:33	7/7/2016 14:40	10353860125	Copper	0.1	1.3	ppm
<b>095-63A Kitchen Sink Faucet (3)</b>	<b>6/26/2016 14:33</b>	<b>7/7/2016 14:40</b>	<b>10353860125</b>	<b>Lead</b>	<b>22</b>	<b>15</b>	<b>ppb</b>
095-64A Kitchen Restroom Sink Faucet	6/26/2016 14:35	7/7/2016 14:42	10353860127	Copper	0.1	1.3	ppm
095-64A Kitchen Restroom Sink Faucet	6/26/2016 14:35	7/7/2016 14:42	10353860127	Lead	6	15	ppb
095-65A Kitchen Utility Closet Sink Faucet	6/26/2016 14:36	7/7/2016 14:43	10353860129	Copper	0.0	1.3	ppm

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Woodstock Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
095-65A Kitchen Utility Closet Sink Faucet	6/26/2016 14:36	7/7/2016 14:43	10353860129	Lead	40	15	ppb
095-66A Cafeteria Drinking Fountain	6/26/2016 14:30	7/7/2016 14:47	10353860131	Copper	0.0	1.3	ppm
095-66A Cafeteria Drinking Fountain	6/26/2016 14:30	7/7/2016 14:47	10353860131	Lead	19	15	ppb
095-67A Garbage Room Sink Faucet	6/26/2016 14:03	7/7/2016 17:45	10353860133	Copper	0.1	1.3	ppm
095-67A Garbage Room Sink Faucet	6/26/2016 14:03	7/7/2016 17:45	10353860133	Lead	2	15	ppb
095-68A Girls Restroom Sink Faucet (1)	6/26/2016 14:35	7/7/2016 14:49	10353860135	Copper	0.1	1.3	ppm
095-68A Girls Restroom Sink Faucet (1)	6/26/2016 14:35	7/7/2016 14:49	10353860135	Lead	8	15	ppb
095-69A Girls Restroom Sink Faucet (2)	6/26/2016 14:37	7/7/2016 14:50	10353860137	Copper	0.1	1.3	ppm
095-69A Girls Restroom Sink Faucet (2)	6/26/2016 14:37	7/7/2016 14:50	10353860137	Lead	17	15	ppb
095-70A Girls Restroom Spigot	6/26/2016 14:40	7/8/2016 07:55	10353860139	Copper	18.6	1.3	ppm
095-70A Girls Restroom Spigot	6/26/2016 14:40	7/7/2016 17:46	10353860139	Lead	510	15	ppb
095-71A Boys Restroom Sink Faucet (1)	6/26/2016 14:05	7/7/2016 17:48	10353860141	Copper	0.3	1.3	ppm
095-71A Boys Restroom Sink Faucet (1)	6/26/2016 14:05	7/7/2016 17:48	10353860141	Lead	12	15	ppb
095-72A Boys Restroom Sink Faucet (2)	6/26/2016 14:06	7/7/2016 14:51	10353860143	Copper	0.1	1.3	ppm
095-72A Boys Restroom Sink Faucet (2)	6/26/2016 14:06	7/7/2016 14:51	10353860143	Lead	22	15	ppb
095-73A Boys Restroom Spigot	6/26/2016 14:07	7/7/2016 17:51	10353860145	Copper	0.2	1.3	ppm
095-73A Boys Restroom Spigot	6/26/2016 14:07	7/7/2016 17:51	10353860145	Lead	16	15	ppb
095-74A Custodial 1 Sink Faucet	6/26/2016 14:13	7/7/2016 14:53	10353860147	Copper	0.1	1.3	ppm
095-74A Custodial 1 Sink Faucet	6/26/2016 14:13	7/7/2016 14:53	10353860147	Lead	55	15	ppb
095-75A Room 1A Sink Faucet	6/26/2016 14:16	7/7/2016 14:54	10353860149	Copper	0.3	1.3	ppm
095-75A Room 1A Sink Faucet	6/26/2016 14:16	7/7/2016 14:54	10353860149	Lead	116	15	ppb
095-76A Room 2A Sink Faucet	6/26/2016 14:21	7/7/2016 14:57	10353860151	Copper	0.2	1.3	ppm
095-76A Room 2A Sink Faucet	6/26/2016 14:21	7/7/2016 14:57	10353860151	Lead	54	15	ppb
095-77A Room 2A Drinking Fountain	6/26/2016 14:24	7/7/2016 14:58	10353860153	Copper	0.0	1.3	ppm
095-77A Room 2A Drinking Fountain	6/26/2016 14:24	7/7/2016 14:58	10353860153	Lead	5	15	ppb
095-78A Room 2A Spigot	6/26/2016 14:28	7/7/2016 17:53	10353860155	Copper	0.1	1.3	ppm
095-78A Room 2A Spigot	6/26/2016 14:28	7/7/2016 17:53	10353860155	Lead	156	15	ppb
095-79A Room 3A Sink Faucet (1)	6/26/2016 14:20	7/7/2016 15:00	10353860157	Copper	0.2	1.3	ppm
095-79A Room 3A Sink Faucet (1)	6/26/2016 14:20	7/7/2016 15:00	10353860157	Lead	104	15	ppb
095-80A Room 3A Sink Faucet (2)	6/26/2016 14:22	7/7/2016 17:54	10353860159	Copper	0.1	1.3	ppm
095-80A Room 3A Sink Faucet (2)	6/26/2016 14:22	7/7/2016 17:54	10353860159	Lead	51	15	ppb
095-81A Room 3A Drinking Fountain	6/26/2016 14:25	7/7/2016 15:15	10353860161	Copper	0.0	1.3	ppm
095-81A Room 3A Drinking Fountain	6/26/2016 14:25	7/7/2016 15:15	10353860161	Lead	5	15	ppb
095-82A Room 4A Sink Faucet	6/26/2016 14:27	7/7/2016 15:23	10353860163	Copper	0.2	1.3	ppm
095-82A Room 4A Sink Faucet	6/26/2016 14:27	7/7/2016 15:23	10353860163	Lead	51	15	ppb
095-83A Room 4A Drinking Fountain	6/26/2016 14:28	7/7/2016 15:24	10353860165	Copper	0.3	1.3	ppm
095-83A Room 4A Drinking Fountain	6/26/2016 14:28	7/7/2016 15:24	10353860165	Lead	6	15	ppb
095-84A Room 5A Sink Faucet	6/26/2016 14:16	7/7/2016 15:26	10353860167	Copper	0.2	1.3	ppm
095-84A Room 5A Sink Faucet	6/26/2016 14:16	7/7/2016 15:26	10353860167	Lead	29	15	ppb
095-85A Room 5A Drinking Fountain	6/26/2016 14:17	7/7/2016 15:27	10353860169	Copper	0.1	1.3	ppm
095-85A Room 5A Drinking Fountain	6/26/2016 14:17	7/7/2016 15:27	10353860169	Lead	2	15	ppb
095-86A Room 2A Sink Faucet	6/26/2016 14:19	7/7/2016 17:56	10353860171	Copper	0.2	1.3	ppm
095-86A Room 2A Sink Faucet	6/26/2016 14:19	7/7/2016 17:56	10353860171	Lead	72	15	ppb

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Woodstock Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
095-87A Room 6A Sink Faucet	6/26/2016 14:14	7/7/2016 15:28	10353860173	Copper	0.2	1.3	ppm
095-87A Room 6A Sink Faucet	6/26/2016 14:14	7/7/2016 15:28	10353860173	Lead	20	15	ppb
095-88A Room 6A Drinking Fountain	6/26/2016 14:15	7/7/2016 15:30	10353860175	Copper	0.2	1.3	ppm
095-88A Room 6A Drinking Fountain	6/26/2016 14:15	7/7/2016 15:30	10353860175	Lead	5	15	ppb
095-89A Room 7A Sink Faucet	6/26/2016 14:10	7/7/2016 15:32	10353860177	Copper	0.1	1.3	ppm
095-89A Room 7A Sink Faucet	6/26/2016 14:10	7/7/2016 15:32	10353860177	Lead	13	15	ppb
095-90A Room 7 Drinking Fountain	6/26/2016 14:12	7/7/2016 15:33	10353860179	Copper	0.0	1.3	ppm
095-90A Room 7 Drinking Fountain	6/26/2016 14:12	7/7/2016 15:33	10353860179	Lead	1	15	ppb
095-91A Womens Restroom Sink Faucet	6/26/2016 14:49	7/6/2016 18:13	10353860181	Copper	0.2	1.3	ppm
095-91A Womens Restroom Sink Faucet	6/26/2016 14:49	7/6/2016 18:13	10353860181	Lead	15.0	15	ppb
095-92A Womens Restroom Sink Faucet	6/26/2016 14:49	7/6/2016 18:19	10353860183	Copper	0.2	1.3	ppm
095-92A Womens Restroom Sink Faucet	6/26/2016 14:49	7/6/2016 18:19	10353860183	Lead	17	15	ppb
095-93A Womens Restroom Spigot	6/26/2016 14:49	7/8/2016 07:57	10353860185	Copper	0.7	1.3	ppm
095-93A Womens Restroom Spigot	6/26/2016 14:49	7/7/2016 17:57	10353860185	Lead	148	15	ppb
095-94A Mens Restroom Sink Faucet (1)	6/26/2016 14:51	7/7/2016 17:58	10353860187	Copper	0.1	1.3	ppm
095-94A Mens Restroom Sink Faucet (1)	6/26/2016 14:51	7/7/2016 17:58	10353860187	Lead	47	15	ppb
095-95A Mens Restroom Sink Faucet (2)	6/26/2016 14:53	7/6/2016 18:20	10353860189	Copper	0.1	1.3	ppm
095-95A Mens Restroom Sink Faucet (2)	6/26/2016 14:53	7/6/2016 18:20	10353860189	Lead	17	15	ppb
095-96A Mens Restroom Spigot	6/26/2016 14:55	7/7/2016 18:00	10353860191	Copper	0.4	1.3	ppm
095-96A Mens Restroom Spigot	6/26/2016 14:55	7/7/2016 18:00	10353860191	Lead	32	15	ppb
095-97A Outside Spigot (1)	6/26/2016 16:06	7/6/2016 18:22	10353860193	Copper	0.1	1.3	ppm
095-97A Outside Spigot (1)	6/26/2016 16:06	7/6/2016 18:22	10353860193	Lead	30	15	ppb
095-98A Outside Spigot (2)	6/26/2016 16:07	7/6/2016 18:23	10353860195	Copper	0.0	1.3	ppm
095-98A Outside Spigot (2)	6/26/2016 16:07	7/6/2016 18:23	10353860195	Lead	16	15	ppb
095-99A Outside Spigot (3)	6/26/2016 16:08	7/6/2016 18:27	10353860197	Copper	0.0	1.3	ppm
095-99A Outside Spigot (3)	6/26/2016 16:08	7/6/2016 18:27	10353860197	Lead	13	15	ppb
095-100A Outside Spigot (4)	6/26/2016 16:13	7/7/2016 18:02	10353860199	Copper	0.1	1.3	ppm
095-100A Outside Spigot (4)	6/26/2016 16:13	7/7/2016 18:02	10353860199	Lead	298	15	ppb
095-101A Outside Spigot (5)	6/26/2016 16:13	7/7/2016 18:04	10353860201	Copper	0.0	1.3	ppm
095-101A Outside Spigot (5)	6/26/2016 16:13	7/7/2016 18:04	10353860201	Lead	12	15	ppb
095-102A Outside Spigot (6)	6/26/2016 16:15	7/6/2016 18:28	10353860203	Copper	0.0	1.3	ppm
095-102A Outside Spigot (6)	6/26/2016 16:15	7/6/2016 18:28	10353860203	Lead	58	15	ppb
095-103A Outside Spigot (7)	6/26/2016 16:16	7/6/2016 18:30	10353860205	Copper	0.0	1.3	ppm
095-103A Outside Spigot (7)	6/26/2016 16:16	7/6/2016 18:30	10353860205	Lead	14	15	ppb
095-104A Outside Spigot (8)	6/26/2016 16:17	7/7/2016 18:11	10353860207	Copper	0.4	1.3	ppm
095-104A Outside Spigot (8)	6/26/2016 16:17	7/8/2016 07:58	10353860207	Lead	1580	15	ppb
095-105A Outside Spigot (9)	6/26/2016 16:20	7/6/2016 18:31	10353860209	Copper	0.0	1.3	ppm
095-105A Outside Spigot (9)	6/26/2016 16:20	7/6/2016 18:31	10353860209	Lead	3	15	ppb
095-106A Outside Spigot (10)	6/26/2016 16:21	7/8/2016 07:59	10353860211	Copper	1.4	1.3	ppm
095-106A Outside Spigot (10)	6/26/2016 16:21	7/7/2016 18:12	10353860211	Lead	329	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Woodstock Elementary School

<b>Sample Identification # and Location</b>	<b>Date/Time Collected</b>	<b>Date/Time Analyzed</b>	<b>Container ID</b>	<b>Analyte</b>	<b>Results</b>	<b>EPA Action Level</b>	<b>Units</b>
---	----------------------------	---------------------------	---------------------	----------------	----------------	-------------------------	--------------

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.